

GREENSBORO FIRE DEPARTMENT
FIRE PREVENTION BUREAU
1514 N. Church Street
Greensboro, N. C. 27405
373-2177

To: Chief of Fire Prevention Bureau, City of Greensboro, N. C.

Application is hereby made by the undersigned for a permit to

☒ Remove Underground Tank(s)

☐ Abandon Underground Tank(s) in or on the premises know as:

Piedmont Truck & Body 533 P/6th St - 650
(Business Name and Address)

1. Tank Contractor: Four Seasons Industrial Services, Inc.

Contractor's Address: 3107 S. Elm-Eugene St.; Greensboro, NC 27406

Number, size and product type of tanks: (3) 10,000

diesel underground storage tanks.

2. Permit shall be obtained for the removal or abandonment of underground tanks in place prior to beginning work.

3. Tank contractor shall be licensed as a General Contractor by City Tax Collections.

4. Removal and abandonment of underground tanks in place shall comply with all applicable codes and regulations including the Fire Code, Guilford County Health Regulations, N.F.P.A. 327, and A.P.I. Publication 1604.

5. Notify Fire Prevention at 373-2177 and Guilford Environmental at 373-3771 prior to removal or abandonment in place.

6. For tank removal or abandonment in place all liquids shall be removed from the tank(s) and properly disposed of in accordance with applicable laws.

7. Prior to removal or abandonment in place tanks shall be purged or rendered inert. Purging or inerting shall be conducted in accordance with applicable standards and regulations. For purging the vapors shall not exceed 20% of the lower flammable limit. For inerting the oxygen content shall be below 8%. Tank contractor shall have the proper operating meters, combustible gas indicator and/or oxygen meter at each job site.

Note: Perchloroethylene will not be allowed as an inerting agent.